

APPENDIX C – WATTAGE SCHEDULE

1. LIGHTING CIRCUITS: PORCHES, HALLWAYS, STAIRWAYS, FOYERS, ATTICS, CLOSETS.

Side or ceiling fixture outlet	60 VA
Convenience Receptacle	150 VA
Roof Exhaust Fan	100 VA
Whole House Fan	500 VA

EXTERIOR

Entrance or exit door, side or overhang fixture outlet	60 VA
Floodlights (per lampholder)	150 VA
Garage side door, side or overhang fixture outlet	100 VA
Convenience outlet	300 VA

SUN PORCH, SOLARIUM, BREEZEWAY, LIBRARY, DEN, STUDY, MUSIC, LIVING, FAMILY, RECREATION, GREAT, EXERCISE, SEWING ROOMS, ETC.

Side fixture outlet	60 VA
Ceiling fixture outlet	150 VA
Convenience outlet	300 VA
Clock, picture and mantel outlet, when located 4" above floor	50 VA

DRESSING AND BEDROOMS

Side fixture outlet	60 VA
Ceiling fixture outlet	150 VA
Convenience outlet	100 VA

BATHROOMS AND LAVATORIES

Exhaust fan	100 VA
Side fixture outlet	100 VA
Ceiling fixture outlet	150 VA
Over the mirror fixture outlet	200 VA

Fan / light outlet	200 VA
Convenience outlet	500 VA
NOTE: Permanent electrical heaters are to be computed at 100% of equipment Rating.	

UNDERFLOOR SPACE (CRAWL SPACE)

Lighting outlet	60 VA
Convenience outlet	100 VA

UNFINISHED BASEMENT OR LOWER LEVEL

Ceiling fixture outlet (per 200 sf)	100 VA
Convenience outlet	150 VA

GARAGE

Ceiling fixture outlet (per car space)	100 VA
Convenience receptacle (per car space)	300 VA
Overhead door motor receptacle	300 VA

**DETACHED GARAGE, if wired,
this section shall apply.**

PADDLE FANS

All rooms	200 VA
-----------	--------

DINING, DINETTE AND BREAKFAST ROOMS

Side fixture outlet	60 VA
Ceiling fixture outlet	300 VA

LAUNDRY AND UTILITY AREA

Side fixture outlet	60 VA
Ceiling fixture outlet	150 VA

KITCHEN AREA

Sink, pantry, under counter fixture outlet	100 VA
Exhaust fan	100 VA
Ceiling fixture outlet	200 VA

2. **APPLIANCE CIRCUITS**

DINING, DINETTE, PANTRY, BREAKFAST ROOM AND WET BARS

Convenience receptacle	500 VA
------------------------	--------

LAUNDRY AND UTILITY AREA

Laundry receptacle	200 VA
Additional receptacle	100 VA

KITCHEN AREA

Refrigerator, freezer, gas range receptacle	500 VA
Convenience receptacle (minimum of 2 circuits to serve the counter top area)	1000 VA
Dishwasher and/or disposal (shall be on a separate 20 ampere circuit with no other item)	2000 VA
Trash compactor, in-line water heater And other stationary or fixed appliances (separate circuit or nameplate rating)	

3. **SEPARATE CIRCUITS**

Furnace and auxiliary equipment, A/C equipment outdoors, water pump, sump pump, heat pump, etc. must be on separate circuits.

4. **LIGHTING CIRCUIT**

Total circuit VA shall not exceed 1500 maximum using a minimum #14 AWG with ground.

5. **APPLIANCE CIRCUIT**

Total circuit VA shall not exceed 2000 maximum using a minimum #12 AWG with ground.